



Catalog No. THQP115

Description: ASM THQP C/B 1 POLE 120/240V

UPC No 783164085679

Home > Circuit Breakers > Residential Circuit Breakers > Feeder Plug-in Circuit Breakers

THQP breakers are a smaller, smarter solution for today's cost- and quality-conscious contractors and homeowners. Half the width of standard breakers, they allow use of smaller load centers and for maximum savings of space and money. GE is the only manufacturer that gives you this cost advantage without sacrificing flexibility. THQP breakers are one-half the width of standard GE breakers but identical in design. They are available from 15 to 50 amps and in single and two pole construction. P115 Amps 15 A

Descriptors	
Category GO Schedule	Feeder Plug-in Circuit Breakers
GO Schedule	R5
Specifications	
Trin Chula	New Interchance his

Transfer of the control of the contr	
Trip Style	Non-Interchangeable
Frame Type	Q-Line
Amperage	15 A
System Voltage	120 Vac, 120/240 Vac
Poles	1
Trip Function	LI
Continuous Current Rated	Standard
120 Vac Interrupting Rating	10 KAIC
120/240 Vac Interrupting Rating	10 KAIC
Suitable for Reverse Feed	Yes
Wire Range (Cu/Al)	14-8 kcmil / 12-8 kcmil
Product Line	Q-Line (Plug-In)
Long Time	Fixed
Instantaneous	Fixed
Protective Relays	No
Current Metering	No
Special Markings	HACR, SWD
GSA Compliance	Yes

Classifications	
UL File #	E11592

geindustrial.com Created on: 08/13/2018

Publications		
Title	Publication No.	Publication Type
PowerMark Gold* Load Centers, Q-Line Circuit Breakers and Accessories Guide	DET1022	Application and
Guide includes product features, photos, product number selection guide, knockout drawings, wiring diagrams, accessories and options list. O-Line Plug-In MCCB, 100A Frame 1-, 2- Pole, Drawing	DET1023	Technical
1-Page fully dimensioned outline drawing in .pdf format	139C5337-SH1	Drawings-Outline and Dimensional

Additional Documentation: Visit our Publication Library to find technical documentation, time current curves, CSI Specifications and promotional literature.

geindustrial.com Created on: 08/13/2018