



 <b>115 Albany Ave</b> <b>Amityville, NY 11701</b> <b>(800) 645-2860</b> <b>www.lambro.net</b>	<b>PROPRIETARY AND CONFIDENTIAL</b> THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF LAMBRO INDUSTRIES, INC. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF LAMBRO INDUSTRIES, INC. IS PROHIBITED.	DESIGN NAME: 2823 4-LOUVER	DRAWN BY: C.Y	APPROVED BY: A.B	 SIZE: <b>A3</b>
		MATERIAL: PP	DATE MODIFIED: 10/5/2023	DO NOT SCALE	
		WEIGHT: 84.37 g	SHRINKAGE:	SCALE: 1:2	SHEET: 1 OF 1



**LAMBRO INDUSTRIES, INC.**

Ventilation Accessories Since 1967

## **FOIL FLEX**

### **UL 2158A CLOTHES DRYER TRANSITION DUCT**

Check with local building codes prior to installation.

**Product:** UL 2158A Clothes Dryer Transition Duct

**Description:** Non-Insulated foil flexible duct reinforced with galvanized wire.

**Construction:** Multiple layers of aluminum / polyester laminate tape formed into a flexible duct bonded with premium heat cured fire retardant adhesive supported by a galvanized wire helix with a wire pitch of 1 inch.

**Components:**

- Aluminum / Polyester laminate
- Hot galvanized zinc coated bead wire - 0.0393 inch diameter
- UL approved fire-retardant water-based adhesive

**Specifications:**

- Wire pitch: 1 inch
- Duct Diameter: 4 inch

**Properties:**

Certified UL2158A - Conforms to all requirements of UL2158A for clothes dryer transition ducts.

- Operating temperature: -86°F to +257°F
- Maximum working pressure: +3000PA
- Resists tearing and puncturing

**NOTE:** Per UL 2158A, only ducts 8 foot lengths or less can be UL marked and installed.