

Combination Type AFCI

Combination Type Arc Fault Circuit Interrupters (AFCI) are required in the 2005 and 2008 NEC (Paragraph 210.12). The Combination Type replaces the Branch Feeder design as specified in the 1999 and 2002 NEC.

The code that your state or municipality is adhering to will determine which breakers to use.

Murray AFCIs have industry leading technology which includes industry exclusive trip indication. This feature saves the contractor time and money by pinpointing the causes and types of breaker trips.

For specific information regarding how AFCIs operate, or to find out which version of the NEC your state or municipality is using, visit : www.murrayconnect.com/afci

Amperage	Branch Feeder	Combination Type
15	MP115AF	MP115AFC
20	MP120AF	MP120AFC



Data Sheet

www.murrayconnect.com/afci

MURRAY

Murray Electrical Products
Siemens Energy & Automation, Inc.
3333 Old Milton Parkway
Alpharetta, GA 30005

1-800-964-4114
info.sea@siemens.com

©2008 Siemens Energy & Automation, Inc.
All Rights Reserved. Siemens is a registered
trademark of Siemens AG. Murray is a registered
trademark of Siemens Energy & Automation, Inc.
Product names mentioned may be trademarks or
registered trademarks of their respective
companies. Specifications are subject to change
without notice.

MYFL-MAFCI-0808 (New)

www.murrayconnect.com/afci