

## G1814BC Eyewash, Wall Mounted, Stainless Steel Bowl and Cover



**Application:** Eyewash for wall mounting. Unit has stainless steel cover to protect bowl from dust, dirt and other contaminants. Two GS-Plus™ spray-type spray heads deliver a flood of water for rinsing eyes.

Spray Head Assembly: Two GS-Plus<sup>™</sup> spray heads. Each head has an internal flow control and filter to remove impurities from the water flow.

**Valve:** 1/2" IPS chrome plated brass stay-open ball valve. Valve is US-made with chrome plated brass ball and Teflon<sup>®</sup> seals.

Bowl: 11-1/2" stainless steel with bowl cover. Cover is raised automatically when flag handle is activated. Cover closes when handle is returned to closed position.

**Mounting:** Heavy duty cast aluminum wall bracket with powder coated finish.

Supply: 1/2" NPT female inlet.

Waste: 1-1/4" NPT female outlet.

Sign: ANSI-compliant identification sign.

Quality Assurance: Unit is completely assembled and water tested prior to shipment.

## **Available Options**

- **HS** Auxiliary hand-held drench hose for rinsing eyes, face or body.
- **T** Chrome plated brass tailpiece and trap with 1-1/2" IPS waste connection.
- **TP** 1-1/2" OD chrome plated brass tailpiece.
- **TMV** G3600LF thermostatic mixing valve precisely blends hot and cold water to deliver warm (tepid) water as required by ANSI Z358.1-2014. Refer to "Tempering Units" section for complete technical and product selection information.

312 447 8100 телерноме gesafety.com

Listed 8116. Units have been tested to and comply with ANSI Z358.1-2014 and the Uniform Plumbing Code. C











**Eyewashes** 


## G1814BC Eyewash, Wall Mounted, Stainless Steel Bowl and Cover



2. UNIT SHOULD BE INSTALLED SO SPRAY HEADS ARE 33"-45"(838mm-1143mm) ABOVE FINISHED FLOOR.

THIS SPACE FOR ARCHITECT/ENGINEER APPROVAL





Sign Included



ETL Listed 101496. Units have been tested to and comply with ANSI Z358.1-2014.

UP

c

tested to and comply with ANSI Z358.1-2014 and the

Listed 8116. Units have been Uniform Plumbing Code.

Due to continuing product improvement, the information contained in this document is subject to change without notice. All dimensions are  $\pm$  1/4" (6mm). rev. on rev. 0115

Guardian Equipment 1140 N North Branch St Chicago, IL 60642

312 447 8100 теlephone 312 447 8101 FACSIMILE gesafety.com