

IMPORTANT SAFETY INFORMATION. READ AND FOLLOW ALL SAFETY INSTRUCTIONS. Follow label information and instructions concerning Wet or Damp Locations, installation near combustible materials, insulation, building materials, and proper lamping. Do not install in areas subject to combustible vapors or gases. Before wiring to power supply and during servicing or relamping, turn off power at fuse or circuit breaker. **All servicing or relamping must be performed by qualified service personnel. Product must be grounded to avoid potential electric shock or other potential hazard. Product must be mounted in locations and at heights and in a manner consistent with its intended use, and in compliance with the National Electrical Code and local codes.** The use of accessory equipment not recommended by the manufacturer or installed contrary to instructions may cause an unsafe condition. Do not block light emanating from product in whole or part, as this may cause an unsafe condition. Do not allow items such as drapes, curtains, screens or the like to come into contact with the product or to block light from the product, as this may cause an unsafe condition.

INSTALLATION INSTRUCTIONS

ARCHITRAK® SYSTEM

FOR PRESCOLITE AKT TRACK ACCESSORIES, FILTERS, BAFFLES, BARN DOORS.

FOR USE WITH PRESCOLITE AKT ONE/TWO CIRCUIT TRACK SYSTEM ONLY

INSTALLATION INSTRUCTIONS, ACCESSORIES

1. Remove baffle from fixture assembly, be careful baffle mounting clips stay in place.
2. Install accessory clips as shown, 4-places.
3. Place accessory holder over outside of fixture, be sure long tab of clip goes on the inside of fixture. Push accessory holder down over fixture until clips seat on edge of fixture.
4. Reinstall baffle into fixture, push down until firmly seated inside fixture. Install proper lamp, see fixture lamp label.
5. Install filters, lens, or louver assembly by spring back clips. Be sure accessories are firmly seated into clips.

SAVE THESE INSTRUCTIONS

