# elastimold Product Specifications

 Issue Date:
 11/12/2012

 Page:
 1 of 2

 File:
 PSS-376LR-W5X

35kV



200A Loadbreak Elbow

# Features:

- 35kV, 200 Amp Loadbreak Elbow
- Fully shielded, fully submersible molded rubber housing
- 100% peroxide-cured construction includes insulation and conductive EPDM materials
- Provision for hot stick operation
- Provision for ground wire connection
- Wide cable range with minimum number of sizes
- Long bi-metal compression lug is standard
- Non-corrosive capacitive voltage test point

### w/ Test Point

376LR-W5X

## 376LR Loadbreak Elbow Connector

## Applications:

The Elastimold® 376LR Elbow Connector is a fully rated 35kV. 200 Amp Class loadbreak connector. It includes provisions for energized operation using standard hot stick tools allowing loadmaking/loadbreak operation and a visible disconnect. It has a standard interface for connecting to 35kV, 200 Amp bushing inserts, junctions and operating accessories. The 376LR is equipped with an integral voltage test point. The 375LR is designed for connecting to and operating 35kV Class, 200 Amp distribution apparatus. It provides a convenient method to connect or disconnect systems. The 376LR allows connection of cables with insulation diameters from .850" (21.6mm) to 1.465" (37.2mm) with only four elbow sizes. (1/0 solid, 345 mil to 4/0 stranded, 345 mil)

## Ratings:

Meets ANSI/IEEE Standard 386, Latest Revision

For 35kV Voltage Class 1 Ø and 3 Ø:

21.1kV Max Phase-to-Ground – Operating Voltage 36.6kV Max Phase-to-Phase 150kV BIL – Impulse Withstand (1.2 x 50 microsecond wave) 50kV AC – One minute withstand 103kV DC – 15 minutes withstand 26kV AC – Corona Extinction @ 3p.C. sensitivity 200 Amp – Continuous and Loadbreak 10kA Sym – 10 Cycles Momentary & Fault Close



# **<**elastimold **Product Specifications**

										lssue D Page: File:	0ate: 11/ PSS-37	12/2012 2 of 2 6LR-W5X
35kV	200A Loadbreak Elbow w/ Tes								Test Point		376LR-W5	<b>K</b>
CATALOG NUMBER SELECTION Step 1 (W) Determine the insulation diameter of the cable. Select the insulation letter code that best straddles the insulation diameter from W table below. Insert code into catalog number. Step 2 Insert conductor material code from the Material Code table. Step 3 (X)											49" 1, 1mm 4.76" 121, 0 3.97" 100, 8m 100, 8m	
	370	6LR	-	Material C Copper* Bi-metal W Code	2	XXX Code	II Ci	NTEF OMF (		SHING J AT IEEE 7		192,
Cable Insulation Diameter in Inches		Cable Insulation Diameter in mm		Symbol		ode	Conductor Size A kcmil		WG or Connector only		ctor only	
MIN. .850	MAX. 1.050	MIN. 21.59	MAX. 26.67	for W H		XXX Code	Stran Com		Solid/ Comp.	mm <sup>2</sup>	Bi- Metal	Copper
.980	1.180	24.89	29.97	J		240	1/0		2/0	53.49	02500240	02702240
1.090	1.310	27.69	33.27	к		250	2/0	)	3/0	67.43	02500250	02702250

#### Example:

1.235

The ordering number for an Elbow Connector for a 1/0 compressed/stranded, 345 mil wall cable with an insulation diameter of 1.045" to 1.145" and test point is 376LR-J5240.

31.37

37.21

L

#### Each kit contains the following:

1.465

1	Elbow connector housing	376BLR-W
1	Bi-metal compression lug	02500 <u>XXX</u>
1	Probe	375LRF
1	Probe wrench	271-94
1	Tube, lubricant	82-08
1	Installation instruction	IS-0359
1	Crimp chart	CC-0024

#### 8155 T&B Boulevard, Memphis, TN 38125

#### Notes:

\* Copper compression lug suitable for all copper conductors only.

3/0

4/0

250

260

270

\*\* Bi-metal compression lug with universal aluminum barrel suitable for copper or aluminum conductors.

4/0

250

85.01

26.67



02500260

02500270

02702260

02702270