**Issue Date:** 10/01/2017 Page: 1 of 4 PSS-262LR-W5X File:

28kV

# 200A Loadbreak Elbow

w/ Test Point

262LR-W5X



# 262LR **Loadbreak Elbow** Connector

# **Applications:**

The Elastimold® 262LR Elbow Connector is a fully rated 28kV, 200 Amp Class loadbreak connector. It includes provisions for energized operation using standard hotstick tools allowing loadmaking/loadbreak operation and a visible disconnect. It has a standard interface for connecting to 28kV, 200 Amp bushing inserts, junctions and operating accessories. The 262LR is designed for connecting to and operating 28kV Class, 200 Amp distribution apparatus. It provides a convenient method to connect/disconnect systems. Elastimold's 28 kV 200 Amp Loadbreak Elbow allows connection of cables with insulation diameters from .575" (20.3mm) to 1.31" (29.7mm) with five elbow sizes (#2 solid to 4/0 stranded, 260 mil). The 261/262 series covers the 0.575" to 1.22" range with four sizes (A to D) and the 275/276 covers the 1.09" to 1.31" range with one size (E).

### Features:

- 28kV, 200 Amp Loadbreak Elbow
- Fully shielded, fully submersible molded rubber housing
- 100% peroxide-cured construction includes insulation and conductive EPDM materials
- Provision for hot stick operation
- Provision for ground wire connection
- Wide cable range with minimum number of sizes
- Long bi-metal compression lug is standard

## Ratings:

Meets ANSI/IEEE Standard 386. Latest Revision

### For 28kV Voltage Class:

16.2kV Max Phase-to-Ground - Operating Voltage 28kV Max Phase-to-Phase

140kV BIL - Impulse Withstand (1.2 x 50 microsecond wave)

45kV AC - One minute withstand

84kV DC - 15 minutes withstand

21.5kV AC - Corona Extinction @ 3pC sensitivity

200 Amp - Continuous and Loadbreak

10kA Sym - 10 Cycles Momentary & Fault Close





**Issue Date:** 10/01/2017 Page: 2 of 4 PSS-262LR-W5X File:

200A Loadbreak Elbow 28kV w/o Test Point 262LR-W5X

**Material Code** 

Copper\*

Bi-metal\*\*

XXX Code

### CATALOG NUMBER SELECTION

### Step 1 (W)

Determine the insulation diameter of the cable. Select the insulation letter code that best straddles the insulation diameter from W table below. Insert code into catalog number.

### Step 2


Insert conductor material code from the Material Code table.

### Step 3 (X)

Choose the proper compression lug code according to the conductor size from the Conductor Code Table. Insert code into catalog number.

### **Example:**

The ordering number for an Elbow Connector for a 1/0 compressed/stranded, 260 mil wall cable with an insulation diameter of .885" to .975" and with a capacitive test point is 262LR-C5240.




Symbol		Cable In Diamete	Cable Insulation Diameter in Inches		
for W	MAX.	MIN.	MAX.	MIN.	
Α	18.80	14.61	0.740	0.575	
В	22.99	16.13	0.905	0.635	
С	26.92	20.45	1.060	0.805	
D	30.99	22.61	1.220	0.890	

### **262LR** Cat # just for Size "E"

Out " 140t 101 0120 2							
Cable Insulation Diameter in Inches			Cable Ins Diamete	Symbol for W			
	MIN.	MAX.	MIN.	MAX.	IOI VV		
	1.090	1.310	27.68	33.27	Е		

### Each kit contains the following:

1	Elbow connector housing	262BLR-W
1	Bi-metal compression lug	02500 <u>XXX</u>
1	Probe	274LRF
1	Probe wrench	271-94
1	Tube, lubricant	82-08
1	Crimp chart	CC-0020
1	Installation Instruction	IS-1380



Code	Conductor Size AWG or kcmil			Connector only	
XXX	Strand./ Compr.	Solid/ Comp.	mm²	Bi- Metal	Copper
190	-	#4	16.76	02500190	02702190
200	#4	#3	21.14	02500200	02702200
210	#3	#2	26.67	02500210	02702210
220	#2	#1	33.62	02500220	02702220
230	#1	1/0	42.41	02500230	02702230
240	1/0	2/0	53.49	02500240	02702240
250	2/0	3/0	67.43	02500250	02702250
260	3/0	4/0	85.01	02500260	02702260
270	4/0	250	107.20	02500270	02702270

### Notes:

- \* Copper compression lug suitable for all copper conductors only
- \*\* Bi-metal compression lug with universal aluminum barrel suitable for copper or aluminum conductors.





**Issue Date:** 10/01/2017 Page: 3 of 4 PSS-262LR-W5X File:

28kV

200A Loadbreak Elbow

w/ Test Point

262LR-W5X

### **IMPORTANT:**

For safety purposes, a sealing & grounding kit with the loadbreak elbow is HIGHLY **RECOMMENDED**. Please choose from the sealing and grounding kit below:

# **Jacket Concentric Neutral Cable**

# **Copper Tape Shield Cable**



**200ECS** 

For Jacketed Concentric Neutral Cables, the sealing kit part number will be: 200ECS or add suffix "-S" to part number for cables with nominal O.D. within the range of .80"-1.50"

### Example:

The ordering number for an Elbow Connector for a 1/0 compressed/stranded, jacketed concentric neutral, 220 mil wall cable with an insulation diameter of .805" to .895", overall cable diameter is 1.03" and capacitive test point is


### 262LR-B5240-S.

For installation instruction for the 200ECS, please see IS-459





**200ECSG3** 



200ECS or add suffix "-S" to part number for cables with nominal O.D. within the range of .80"-1.50"

#### **Example:**

The ordering number for an Elbow Connector for a 1/0 compressed/stranded, copper tape shield, 220 mil wall cable with an insulation diameter of .805" to .895", overall cable diameter is 1.05" and capacitive test point is

262LR-B5240-SG3.

For installation instruction for the 200ECSG3, please see IS-460







**Issue Date:** 10/01/2017 4 of 4 Page: PSS-262LR-W5X File:

28kV

200A Loadbreak Elbow

w/ Test Point

262LR-W5X


### Unishield Cable

### 10TL-W

For Unishield Cables, the shield adapter part number will be:

10TL-W, where the "W" letter code will be determined by the insulation diameter of the Unishield cable. Please see W Table below for W code. Or add suffix "-TL" to the part number.





38.9

40.0

44.8

41.7

42.8

47.6

KAB

KB

РΒ

### **Example:**

1.640

1.685

1.875

1.530

1.575

1.765

The ordering number for an Elbow Connector for a 1/0 compressed/stranded Unishield, 220 mil wall cable with an insulation diameter of .825" to .9.35', overall cable diameter is 1.03" and capacitive test point is TL-GAB Plus the kit 262LR-B5240-S

## Copper Tape **Shield Cable**

# Concentric **Neutral Cable**



### Example:

Partial installation example of 262LR-B5240-SG3 for copper tape shield cables. For full instruction please see IS-460.

### **Example:**

Partial installation example of 262LR-B5240-S for concentric neutral cables. For full instruction please see IS-459.

