# T&B Conduit Fittings

# **Liquatite® Flexible Conduit — Steel**

## Type ATLA—All Temperature





Trade Size			Reel Content*		Reel Content*	Inside Bend Radius		Wt.	
(in.)	Cat. No.	(m)	Cat. No.	(m)	Cat. No.	(m)	in.	(mm)	kg/30m
3/8	ATLA038-30	30	ATLA038-150	150	ATLA038-300	300	2.0	(50.8)	13
1/2	ATLA050-30	30	ATLA050-150	150	ATLA050-300	300	3.0	(76.2)	15
3/4	ATLA075-30	30	ATLA075-150	150	ATLA075-300	300	4.2	(106.7)	24
1	ATLA100-30	30	ATLA100-120	120	-	-	5.5	(139.7)	37
1-1/4	ATLA125-15	15	ATLA125-60	60	-	-	7.0	(177.8)	46
1-1/2	ATLA150-15	15	ATLA150-45	45	-	-	4.5	(114.3)	47
2	ATLA200-15	15	ATLA200-30	30	-	-	6.0	(152.4)	66
2-1/2	ATLA250-8**	8	-	-	-	-	8.0	(203.2)	87
3	ATLA300-8**	8	-	-	-	-	10.0	(254.0)	114
3-1/2	ATLA350-8**	8	-	-	-	-	11.0	(279.4)	140
4	ATLA400-8**	8	-	-	-	-	12.0	(304.8)	154

See Chart on p.155 for dimensions and tolerances.

#### Type ATLA

A liquidtight flexible steel conduit designed specifically for extreme hot or cold environments. The flexible inner core is identical to that found in Type LA. The specially formulated PVC jacket remains flexible at low temperatures and resists ageing at elevated temperatures. It is listed UL and certified CSA.

#### Construction

ATLA has a flexible inner core made from a spiral wound strip of heavy gauge, hot-dipped galvanized steel. The 3/8 through 1-1/4 inch trade sizes contain an integral bonding strip of copper. The 1-1/2 and larger sizes are designed with a fully interlocked strip.

The jacketing material is a rugged flame retardant flexible PVC resistant to weathering. UV. oils and many chemicals. Refer to the Conduit - Chemical Resistance Guide beginning on p.158.

#### **Applications**

Designed to be used with high temperature machine tool wiring. Ideal for outdoor installations in cold climates. This conduit is intended for installation with Rule 12-1300 of Canadian Electrical Code (CEC) Part I 2002.

The use of a separate bonding conductor is mandatory in accordance with CEC Rule 12-1306 for Ordinary Locations.

The use of Liquidtight Flexible Conduit with sign and Outline Lighting are in accordance with CEC Rule 34-400 (2).

- -Listed and marked for direct burial and in poured concrete.
- -For containment of 600-volt and lower potential circuits.

### **Working Temperatures**

-55°C to 105°C Air/60°C Wet/70°C Oil

### Listing/Certification



ANSI/ UL-360 for Liquidtight Flexible Steel Conduit.



Conforms to the requirements of Section 16 & 17.7 of the ANSI/NFPA-79 Electrical Standard for Industrial Machinery.

#### Standard Colour

Machine tool grey



<sup>\*</sup> See p.155 for label and packaging detail.

<sup>\*\*</sup> Not CSA Certified.