### inSIGHT

### Circuit-Lock Disconnect

## with LED Indicators

# HUBBELL

### **Features**

- Six highly visitble integral phase indentification LEDs
- Secondary confirmation of isolation of power
- Certified by NSF
- Highly visible red handle meets OSHA LO/TO capabilities
- 15 degree sloped top support hygenic design

## **Ordering Information**

Description SS Sloped Disc, 100A LED, 4X, Rep Cover

**UPC Number** 783585640501 Catalog number HBLDS10SSRRCP

## Listings

cULus Listed NSF

### **Specifications**

**Environmental rating** UL Witnessed IP69K, 4X and 12

Enclosure: Base and Top 304 Stainless Steel

Handle PBT Conduit Hub 1 1/4" Zinc **Enclosure Gasket** Neoprene Frame Galvanized Steel

**Enclosure Screws** Stainless Steel 300 Series

Shaft (Unfused)

Shaft Seal Molded Neopren

PC LED Lense

## 4 MOUNTING SCREWS ON 6.54 [166.1] 000 LED INDICATORS

### **Complementary Products**

"Break After Main" 1NO & 1 NC Aux

Contact

"Break Before Main" 1NO Aux Contact 1 1/4" Stainless Steel Conduit Hub

HBLAC1

HBLAC2 HUB125SS

### **Performance**

Dielectric Voltage

Max. Working Voltage

## **Electrical**

Certified for current interrupting at full rated **Current Interrupting** 

current and voltage

Withstands 3000V AC minimum

600V AC RMS

**Short Circuit Current Ratings** (SCCR): (Motor Disconnect) Suitable for use on (SCCR): (Motor Disconnect) à circuit capable of delivering not more than

65kA RMS symmetrical, 600V AC max. when protected by Class J fuses rated 30A max.

### Mechanical

In accordance with UL 746C Impact Resistance Mounting External fully adjustable feet

Terminal Identification In accordance with UL, CSA and international

conventions

### **Environmental**

Flammability UL94-5VA and V0 Classification

Indoor and Outdoor - Type 4X (Wash down, Moisture Resistance

Corrosion resistant); Indoor - Type 12 (Dust-tight, Falling Dirt, Noncorrosive Liquids).

Operating Temperature Max. Continous: 75°C; Min. Continuous: -40°C

without impact

### **Online Resources**

Customer Use Drawing

eCatalog

Installation Instructions

