Product information presented here reflects conditions at time of publication. Consult factory regarding discrepancies or inconsistencies.

PUMP COMPANY

Zoeller Family of Water Solutions

MAIL TO: P.O. BOX 16347 • Louisville, KY 40256-0347 SHIP TO: 3649 Cane Run Road • Louisville, KY 40211-1961 (502) 778-2731 • 1 (800) 928-PUMP • FAX (502) 774-3624 SECTION: 2.50.040 FM0486 0414 Supersedes 0910

US LISTED

US LISTED

visit our web site: www.zoeller.com

**NEMA 1 ENCLOSURE** 

**NEMA 4X ENCLOSURE** 

Products may not be exactly as illustrated

24

# **ELECTRICAL ALTERNATOR CONTROL PANEL - FOR DUPLEX INSTALLATIONS**

An Electrical Alternator is used on a Duplex pump application where automatic alternation of the pumps is desired for added protection in residential or commercial applications. With one pump operating to handle normal flow, a second pump becomes operational in the event the water level continues to rise. The built-in alarm system, a standard feature, can be connected to sound when the second pump becomes operational (3-float switch system) or independently (4-float switch system). All electrical systems must be installed by a qualified electrician and according to the National Electrical Code. (See Section 430-71 though 430-113, plus any others that apply.)

10-0092

10-0093

#### **Control Panel Features:**

- · Hand-Off-Auto Toggle Switch for each pump
- · Green pump run pilot light for each pump
- · Alarm test and silence switches
- Red pilot light (Nema 1 Only) and audible alarm with 83 to 85 decibel rating for a high water condition
- · Red Alarm Beacon included with Nema 4X enclosure
- · Auxiliary Dry Contact
- High Water Alarm
- · On Single Phase Circuit breaker for each pump
- On Three Phase Motor protective switch with overload protection
- · Magnetic starter for each pump
- · Alternating mechanism
- Numbered terminal strip for connecting pumps and variable level float switches
- Nema 1 general purpose or Nema 4X - Watertight enclosures available
- Integral auxiliary terminal board connections (dry contact) for remote alarm devices
- 3 or 4 variable level float switch control operation
- · Three 20' float switches included with single phase panels
- · 2 Year Warranty
- The use of off-the-shelf components provide for relatively easy field maintenance and repair
- Float switches not included with three phase panels (See FM0526)


## CONTROL PANEL USED WITH SINGLE PHASE PUMPS

NEMA 1 ENCLUSURE WITH 20' FLOAT SWITCH					
Order No.	Dimensions H x W x D	Volts	Amp Range		
10-1039 10-1040	12" x 10" x 6" 12" x 10" x 6"	115 115	7-15 15-20		
10-0092	12" x 10" x 6"	115/200/230	0-20		

#### NEMA 4X ENCLOSURE WITH 20' FLOAT SWITCH

Order No.	Dimensions H x W x D	Volts	Amp Range	
10-1041 10-1042	12" x 10" x 6" 12" x 10" x 6"	115 115	7-15 15-20	
10-1043 10-1044 10-1045 10-1046	12" x 10" x 6" 12" x 10" x 6" 12" x 10" x 6" 12" x 10" x 6" 12" x 10" x 6"	115/200/230 115/200/230 115/200/230 115/200/230	0-7 7-15 15-20 20-30	
10-0093	12" x 10" x 6"	115/200/230	0-20	


\* Branch circuit protection provided by installing electrician.



## **CONTROL PANEL USED WITH THREE PHASE PUMPS**

NEMA 4X ENCLOSURE (Float Switches not included)				
Order No.	Dimensions H x W x D	Volts*	Amp Range	
10-1102 10-1104 10-1106 10-1108 10-1110 10-1111 10-1112 10-1114 10-1115 10-1183	14" x 12" x 6" 14" x 12" x 6"	200/230/460 200/230/460 200/230/460 200/230/460 200/230/460 200/230/460 200/230/460 200/230/460 200/230/460 200/230/460	1.0 - 1.6 1.6 - 2.5 2.5 - 4.0 4.0 - 6.3 6.0 - 10.0 9.0 - 14.0 13.0 - 18.0 17.0 - 23.0 20.0 - 25.0 23.0 - 32.0	
10-1154 10-1156 10-1158	14" x 12" x 6" 14" x 12" x 6" 14" x 12" x 6"	575 575 575	1.6 - 2.5 2.5 - 4.0 4.0 - 6.3	

\*Three phase panel has multi-tap transformer with secondary fusing.



## Sequence of Operation for Duplex Panel

- 1. Operation can begin after the following:
  - Correct voltage is supplied to Panel
  - Panel is properly grounded
  - Pumps are connected correctly to Panel
  - Panel Circuit Breakers are closed
  - Floats are installed properly
  - Overload Protection is adjusted to Pump nameplate amps
  - Pump HOA Switches are set to "Auto"
  - Control On/Off Switch is set to "On"
- When the "Stop" and "Lead" floats are closed Pump 1 will energize and the Pump 1 Pump Run Light will illuminate. Pump 1 will remain operational until the "Stop" float opens.
- 3. The next time the "Stop" and "Lead" floats are closed the Alternating Circuit will energize Pump 2 and the Pump 2 Pump Run Light will illuminate. Pump 2 will remain operational until the "Stop" float opens. This cycle will repeat each time the fluid level rises and falls.
- 4. If the fluid level continues to rise after the first pump has been energized the "Lag" float will close. When the "Lag" float has closed the second Pump will Energize. Both Pumps will remain operational until the "Stop" float opens.

- 5. In a three float system when the "Lag" float is closed the following will also occur:
  - The External High Water Light will illuminate
  - The Audible High Water Horn will sound
  - The Auxiliary Dry Contacts will close
- 6. In a four float system, the alarm float should be the third float causing an alarm to sound when the lead pump fails to operate or the rate of in flow into the basin exceeds the capacity of one pump. When the alarm float is closed the following will occur.
  - The External High Water Light will illuminate
  - The Audible High Water Alarm will sound
  - The Auxiliary Dry Contacts will close

As the liquid level continues to rise the fourth float will close, energizing the lag pump. The lag pump and the lead pump will remain energized until the "Stop" float opens.

NOTE: In Duplex systems where it is considered normal for two pumps to operate in tandem during peak flow conditions, the third and fourth float may be reversed.

 The Audible High Water Horn can be silenced by pressing the Alarm Silence Button. When the "Alarm" float opens the External High Water Light, Audible High Water Horn and Dry Auxiliary Contacts will be reset.

WARNING All electrical systems must be installed by a qualified licensed electrician and according to the National Electrical
Code. (See section 430-71 through 430-113 plus any others that apply)

Refer to FM0712 for correct selection of Electrical Alternator.